

ALL INDIA INSTITUTE OF MEDICAL SCIENCES
Bilaspur, Himachal Pradesh

No. AIIMS-BLS/(G)/2022/NIQ/5

Dated: 13.04.2022

NOTICE INVITING QUOTATION

Supply of Filled Medical oxygen & other cylinders & related items

Sealed quotations are invited from registered stockists/ distributors/ manufacturers having GST No. / for Supply of Filled Medical oxygen & other cylinders & related items as per the detailed specifications (Annexure-O). Sealed Quotations in a single envelope duly super subscribed at the top of the envelope as **“Quotation No. AIIMS-BLS/Stores/2022/NIQ/12 for the supply of Filled Medical oxygen & other cylinders & related items due date of opening 26.4.2022”** containing both the “Technical Bid” and “Price Bid” (in two separate envelopes) may be submitted so as to reach on or before 26.4.2022 up to 11:00 A.M in Stores Section, First Floor- AYUSH Block, AIIMS Bilaspur, Kothipura, Bilaspur, Himachal Pradesh PIN- 174001. Bidders can quote for one or all the items. Late bids will not be considered. The bids shall be opened in the presence of duly constituted purchase committee and bidders who may wish to be present on the same day at 11:30 A.M. For the purpose of technical evaluation, the bidder is required to submit following documents.

Technical Bid:

1. Profile-Name & Full Address of the firm & year of establishment.
2. Copy of permanent GST registration certificate.
3. Copies of supply orders secured during 2021-22 for the similar products.
4. Previous two Income Tax Returns of the bidding entity.
5. Self-declaration that the firm is not debarred by MoHFW or Department of Commerce.
6. Full description, make and quantity of the item must be mentioned in the quotation.
7. On site demo of the items is required to ensure compatibility.

In case the Technical Committee rejects a sample (if asked for) or the bid is “Not Qualified” on technical grounds, the financial bid in respect of that item will not be considered.

Financial Bid: The Rates and total cost must be quoted in both words and figures (over writing not allowed). Selection will be made purely on the basis of lowest price quoted by technically qualified firms. Validity of the quotation should be for a minimum period of 90 days in case discrepancy between unit price & total price, the unit price shall prevail.

Financial Bid submission format for items with quantity required is as under: -

Sr. No.	Item Detail	Qty Required	Make	Model	HSN Code	Unit Price	GST @	Unit price with tax	Total Amount

Other terms and conditions will be as follows: -

1. Supply will be F.O.R. at AIIMS-Bilaspur
2. Supply will have to be arranged within 15 days from the issue of supply order. Delayed supplies beyond 15 days from the date of Supply Order will be subject to LD @0.5% per week or part thereof, on the contract price subject to maximum of 10% of contract price beyond which the supply order will be liable to be cancelled.
3. Supply must conform to samples wherever asked for.
4. The Institute reserves the right to reject the goods if the same are not found in accordance with the specifications approved/ asked for. In case there is a short/defective supply, the firm will be informed and the defective material will be lifted from the concerned department/ Store by the supplier at their own cost within two weeks period. The Institute will not bear any expenses on this account.
5. Samples will be preserved till final settlement.
6. Bidder is required to quote rate of 100% items.
7. Part supply will not be accepted.
8. No revision in rate (on higher side) will be accepted at any stage.
9. The firm shall not assign or sublet the work/job or any part of it to any other firm.
10. Billing will be in the name of Executive Director, AIIMS-Bilaspur. Payment will be made after the item has been received, inspected & accepted. No advance payment will be made at any stage.
11. Taxes at other government levies will be paid extra as applicable.
12. Venue for sample verification (if asked for) and quotation opening shall be in conference hall of AYUSH Block of AIIMS-Bilaspur.
13. In case manufacturer participates, dealers will not be allowed or disqualified.
14. For any query, please contact Dr. Mohammad Kausar, S.S.O. 01978-292575, E-mail stores.aiimsbilaspur@gmail.com

Faculty In Charge
Procurement & Store
AIIMS-Bilaspur
H.P.

Annexure- "O"

List of Items with Description is as follow:

S. No	Name of item	Quantity	Specification
1.	Type A Oxygen Cylinder with Pin Index cylinder valve	04	<ul style="list-style-type: none">- Gas capacity- 0.75 CuM- Water capacity- 5 liter- Length- 735 mm approx.- Minimum wall thickness- 4.0 mm, outer diameter- 108 mm- Should have a neck ring- Should be supplied with pin Index valve system- Maximum Working pressure 150 bar- Purity of Medical Grade Oxygen Gas when tested as per Indian Pharmacopeia (Latest),- Minimum (%) V/V- 99%- Oxygen gas in the Cylinder should conforms to IP- Supply of Medical grade Oxygen gas in CCE approved cylinders only- ISI marked Valve conforming to IS 3224-2002 (Latest) fitted with the cylinder- Validity of Cylinder safety certificate- minimum 5 years- Valve protection caps should be available- All fittings should be leak proof- Each cylinder should be engraved with the details viz (a) Serial No of cylinder/Identification, (b) Code of manufacturing, (c) Working pressure, (d) Water capacity in liters, (e) Test pressure in Kg/cm², (f) Year of manufacture and testing, (g) Tare weight of the cylinder- All the cylinders should be properly painted as per their respective color code, Cylinder No, name of the supplier, name of the gas cylinder and its contents should be clearly indicated on the neck of the cylinder.- All cylinders must have 5year PESO filling permission.- Testing of Cylinder as per standard protocol will be the responsibility of Cylinders supplier.- Availability of BIS Inspection Certificate.- History cards of the cylinders as per Gas

			<p>Cylinder Rules 2016 and rules made thereafter, as amended from time to time should be made available with filled Cylinder supplies, if owner of the Cylinder is supplier</p> <ul style="list-style-type: none"> - Availability of Cylinder filling license (Form F) from Chief Controller of Explosives, Department of Petroleum, Government of India - In case of manufacturer to manufacture and supply medical grade Oxygen gas in cylinders to IP as per Govt of India guide lines, availability of valid license (Form 25 & Form 26) from Drug Control or any appropriate authority is mandatory - Availability of valid Drug License - On site demonstration to be provided to ensure compatibility with available Mindray anesthesia work station at AIIMS, Bilaspur. - Cylinder should be fully filled at the time of supply and the same should be checked and verified. - Any leak/defect in cylinders will be resolved/replaced by the supplier only.
2.	Type A N2O Cylinder with Pin Index Cylinder Valve	04	<ul style="list-style-type: none"> - Water capacity- 5 liter - Length- 735 mm approx. - Minimum wall thickness- 4.0 mm, outer diameter- 108 mm - Should have a neck ring - Should be supplied with pin Index valve system - Maximum Working pressure 150 bar - ISI marked Valve conforming to IS 3224-2002 (Latest) fitted with the cylinder - Validity of Cylinder safety certificate- minimum 5 years - Valve protection caps should be available - All fittings should be leak proof - Each cylinder should be engraved with the details viz (a) Serial No of cylinder/Identification, (b) Code of manufacturing, (c) Working pressure, (d) Water capacity in liters, (e) Test pressure in Kg/cm square, (f) Year of manufacture and testing, (g) Tare weight of the cylinder - All the cylinders should be properly painted as per their respective color code,

			<p>cylinder No, name of the supplier, name of the gas cylinder and its contents should be clearly indicated on the neck of the cylinder</p> <ul style="list-style-type: none"> - All cylinders must have 5year PESO filling permission - Testing of Cylinder as per standard protocol will be the responsibility of cylinders supplier - Availability of BIS Inspection Certificate. - History cards of the cylinders as per Gas cylinder Rules 2016 and rules made thereafter, as amended from time to time should be made available with filled cylinder supplies, if owner of the Cylinder is supplier - Availability of Cylinder filling license (Form F) from Chief Controller of Explosives, Department of Petroleum, Government of India - In case of manufacturer to manufacture and supply medical grade Oxygen gas in cylinders to IP as per Govt of India guide lines, availability of valid license (Form 25 & Form 26) from Drug Control or any appropriate authority is mandatory - Availability of valid Drug License - On site demonstration to be provided to ensure compatibility with available Mindray anesthesia work station at AIIMS, Bilaspur. - Cylinder should be fully filled at the time of supply and the same should be checked and verified. - Any leak/defect in cylinders will be resolved/replaced by the supplier only
3.	MOX connector for Jumbo/Type D Cylinder	04	<ul style="list-style-type: none"> - Compatible to connect Schrader probe of oxygen hose pipe to Type D/Jumbo cylinders (capacity approx. 7000 liters). - On site demonstration to be provided to ensure compatibility and functionality.